

**CITY OF NEW ROCHELLE**  
**DEPARTMENT OF PUBLIC WORKS - ENGINEERING**  
**EPA 02-2015 -3034 OUTFALL SAMPLING**

NY Water Quality Standards = 2,000 MPN/ 100ml Fecal & 10,000 MPN/ 100ml Total Coliform

| LOCATION                                 | SAMPLE DATE | LAB SAMPLE RESULTS<br>FECAL<br>PER 100 ml | COLIFORM<br>PER 100 ml | Discharge Ratings<br>Obvious/Suspect/<br>Potential/Unlikely |
|--|-------------|---|------------------------|---|
| GLEN ISLAND / WOODLAND AVE OUTFALL       | 9/27/2013   | 1,100                                     | 5,000                  | Unlikely  |
|  | 4/14/2015   | 490                                       | 1,100                  | Unlikely  |
|  | 6/10/2015   | 78  | 230                    | Unlikely  |
| *  | 9/29/2015   | N/A                                       | N/A                    |   |
| *  | 10/6/2015   | N/A                                       | N/A                    |   |
| CHURCH STREET OUTFALL                    | 9/27/2013   | 1,300                                     | 3,000                  | Unlikely  |
|  | 4/14/2015   | 24,000                                    | 35,000                 | Potential   |
| *  | 6/10/2015   | N/A                                       | N/A                    |   |
| *  | 9/29/2015   | N/A                                       | N/A                    |   |
|  | 10/6/2015   | 9,200                                     | 35,000                 | Potential   |
|  | 6/22/2017   | 33,000                                    | 79,000                 | Potential   |
| NEW ROCHELLE PUBLIC MARINA               | 9/27/2013   | 170                                       | 5,000                  | Unlikely  |
|  | 4/14/2015   | 1,700                                     | 4,600                  | Unlikely  |
|  | 6/10/2015   | 3,500                                     | 5,400                  | Unlikely  |
| *  | 9/29/2015   | N/A                                       | N/A                    |   |
| *  | 10/6/2015   | N/A                                       | N/A                    |   |
| BOSTON POST RD & STEPHENSON BLVD OUTFALL | 9/27/2013   | 3,000                                     | 24,000                 | Potential   |
|  | 4/14/2015   | 3,100                                     | 92,000                 | Potential   |
|  | 6/10/2015   | 2,400                                     | 5,400                  | Unlikely  |
|  | 9/29/2015   | 23,000                                    | 170,000                | Potential   |
| *  | 10/6/2015   | N/A                                       | N/A                    |   |
|  | 1/18/2017   | 2,800                                     | 16,000                 | Potential   |
|  | 6/22/2017   | 49,000                                    | 79,000                 | Potential   |

\* = N/A = Not Applicable to Collect Sample